

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7135-1591:154 Page 1 of 1

CATEGORY: Audible Signal Devices

LISTEE: Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243
Contact: Leon Newsome (941) 739-4276 Fax (941) 739-4334

DESIGN: Models 2450-H, 2450-M, 2445, 681-1B, 682-1B, 682-1⁽¹⁾-HR, 682-1⁽¹⁾-HW, 691-2B, 692-1B, 692-6B, 692-5, 692-7 and 692-8 horns and horn/strobes.

Units may be followed by a suffix to designate color only. Superscript ⁽¹⁾ indicates marketing reference. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as audible and audible/visual signaling devices for use with separately listed compatible control units. Models 692-5, 692-7, 692-8, 2450-H and 2450-M are suitable for hearing impaired application. The 692 Series and Models 2450-H, -M are for indoor use only.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

NOTE: Formerly 7135-0073:149, 7135-1388:147

11-02-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 17, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager